

WYOMING WATER WORKS WATER QUALITY INFORMATION

Year	MG/mth	raw pH	settled pH	Effluent pH	Distrib. pH	Raw T- alkalinity (mg/l)	Settled T- alkalinity (mg/l)	Settled p- alkalinity (mg/l)	Finished T-alkalinity (mg/l)	Finished P-Alkalinity (mg/l)	Raw T-hardness (mg/l)	Filtered T-hardness (mg/l)	Raw Ca-hardness (mg/l)	Filtered Ca-hardness (mg/l)	Raw Mg-hardness (mg/l)	Filtered Mg-hardness (mg/l)
2006	26.700	7.34	9.66	8.91	8.80	397	67	25	42	5.75	533	173	151	28	38	25
2007	32.290	7.26	9.66	8.90	8.72	397	70	25	49	6.17	513	169	143	27	38	25
2008	26.070	7.44	9.60	9.01	8.86	408	82	26	57	7.81	522	176	143	26	41	27
2009	22.420	7.43	9.42	8.71	8.64	402	92	25	74	6.25	509	188	141	28	38	29
2010	22.030	7.35	9.37	8.76	8.71	405	94	23	73	7.16	500	184	139	26	37	29
2011	21.410	7.32	9.35	8.69	8.65	399	98	25	77	6.74	495	193	142	27	34	31
2012	27.430	7.35	9.50	8.71	8.64	397	87	25	72	6.07	489	186	138	26	35	29
2013	23.410	7.36	9.47	8.68	8.63	399	91	27	77	6.54	508	189	144	28	36	29
2014	22.000	7.38	9.42	8.75	8.72	400	82	23	69	7.24	502	185	154	24	29	31
2015	21.310	7.32	9.26	8.62	8.64	395	86	21	70	6	495	183	154	23	28	30
2016	22.047	7.29	9.22	8.70	8.69	395	88	23	69	8	502	175	133	23	42	29
2017	20.381	7.34	9.29	8.73	8.77	397	89	23	75	10	502	179	132	21	42	31
2018	20.686	7.35	9.37	8.74	8.76	395	84	23	74	10	498	176	133	21	41	30
2019	22.535	7.24	9.24	8.78	8.73	389	90	22	74	10	499	178	133	21	44	31
2020	21.335	7.280	9.190	8.75	8.67	396	91	21	73	9	507	180	129	21	46	31